

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch
690 Walnut Ave.St. 150
Vallejo, CA 94592-1133
(707) 649-5453
(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 69.28**WELDING INSPECTION REPORT****Resident Engineer:**Pursell, Gary**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-007101**Date Inspected:** 09-Jun-2009**Project Name:** SAS Superstructure**OSM Arrival Time:** 645**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 1845**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai ,China**CWI Name:** Li Yan Hua**CWI Present:** Yes No**Inspected CWI report:** Yes No N/A**Rod Oven in Use:** Yes No N/A**Electrode to specification:** Yes No N/A**Weld Procedures Followed:** Yes No N/A**Qualified Welders:** Yes No N/A**Verified Joint Fit-up:** Yes No N/A**Approved Drawings:** Yes No N/A**Approved WPS:** Yes No N/A**Delayed / Cancelled:** Yes No N/A**Bridge No:** 34-0006**Component:** OBG Assembly**Summary of Items Observed:**

On this date CALTRANS OSM Quality Assurance (QA) Inspector was present during the times noted above for observations relative to the work being performed.

Blast Shop

Segment 5CW

This QA Inspector performed a preliminary random visual inspection of the internal bottom structure of this segment after the grit blast. Areas that were marked to be ground were repaired and areas that were marked to be welded were taped and noted to be repaired at the trial assembly yard. The ZPMC (QA) representatives were not present at the time of inspection.

Trial Assembly yard

Segment 4BW

This QA Inspector performed Ultrasonic testing (UT) of approximately 10% of the area previously tested and accepted by ZPMC Quality control personnel. This QA inspector generated a (UT) report for this date. The members are identified as the transverse deck stiffeners in way of the cross beam. The Weld Designations are as follows:

SEG019E-074, 110, 137, 140 and 173.

Unless otherwise noted, all work observed on this date appeared to generally comply with applicable contract documents.

WELDING INSPECTION REPORT

(Continued Page 2 of 2)

Summary of Conversations:

No Relevant conversations

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Eric Tsang, (15000422372), who represents the Office of Structural Materials for your project.

Inspected By:	Patterson,Rodney
----------------------	------------------

Quality Assurance Inspector

Reviewed By:	Carreon,Albert
---------------------	----------------

QA Reviewer
